



# REPORT OF PERFORMANCE

1088-15

**OBJECT** Three-core heat-shrinkable outdoor termination

**TYPE** GTM-OXAS-1233H6A ( GXO-13 )  
6,35/11 (12) kV – 3x185 mm<sup>2</sup> – Al – XLPE

**CLIENT** Gala Shrink Fit  
Mumbai, India

**MANUFACTURER** Gala Shrink Fi  
Mumbai, India

**TESTED BY** KEMA Nederland B.V.  
Arnhem, The Netherlands

**DATE OF TESTS** 12 August 2014 to 23 March 2015

**TEST SPECIFICATION** The programme was based on  
IEC 60502-4 (2010), test sequence 1.1, 1.2, and 1.5.

**SUMMARY AND CONCLUSION** The outdoor termination passed the electrical and non- electrical tests.  
During the examination of the outdoor terminations after the salt fog test  
loss of dielectric quality due to tracking and/or erosion was found.

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

This report consists of 70 pages in total.

Copyright: Only integral reproduction of this report is permitted without written permission from KEMA. Electronic copies in e.g. PDF-format or scanned version of this report may be available and have the status "for information only". The sealed and bound version of the report is the only valid version.

KEMA Nederland B.V.

S.A.M. Verhoeven  
Director Testing, Inspections &  
Certification The Netherlands

Arnhem, 7 May 2015

CONTENTS		page
1	Identification of the object tested .....	4
1.1	Ratings/characteristics of the object tested and proved by tests .....	4
1.2	Characteristics of the outdoor termination for cables with extruded insulation .....	4
1.3	Characteristics of the test cable .....	4
1.4	List of drawings .....	7
2	General information .....	8
2.1	The tests were witnessed by .....	8
2.2	The tests were carried out by .....	8
2.3	Measurement uncertainty .....	8
3	Test sequence 1.1 for outdoor termination (two terminations) .....	9
3.1	Determination of the cable conductor temperature .....	9
3.1.1	Determination of the cable conductor temperature .....	9
3.2	Photograph of test set-up .....	10
3.3	DC voltage dry .....	11
3.4	AC voltage dry .....	12
3.5	AC voltage wet .....	13
3.6	Partial discharge at ambient temperature .....	14
3.7	Impulse voltage at elevated temperature .....	15
3.8	Heating cycle voltage in air .....	23
3.9	Immersion .....	24
3.10	Partial discharge at elevated and ambient temperature .....	25
3.10.1	Partial discharge at elevated temperature .....	25
3.10.2	Partial discharge at ambient temperature .....	26
3.11	Impulse voltage at ambient temperature .....	27
3.12	AC voltage dry .....	35
3.13	Examination .....	36
3.13.1	Photographs .....	37
4	Test sequence 1.2 for outdoor termination (one termination) .....	39
4.1	Test arrangement .....	39
4.1.1	Determination of the cable conductor temperature .....	39
4.2	DC voltage dry .....	40
4.3	AC voltage dry .....	41
4.4	Thermal short circuit test (screen) .....	42
4.5	Thermal short circuit test (conductor) .....	45
4.6	Test circuit S01 .....	46
4.7	Test results and oscillograms .....	47
4.8	Condition / inspection after test .....	49
4.9	Impulse voltage at ambient temperature .....	52
4.10	AC voltage dry .....	60
4.11	Examination .....	61
4.11.1	Photographs .....	62

5	Test sequence 1.5 (one outdoor termination).....	64
5.1	Salt fog .....	64
6	Drawing .....	69
7	Measurement uncertainty .....	70

## 1 IDENTIFICATION OF THE OBJECT TESTED

### 1.1 Ratings/characteristics of the object tested and proved by tests

Rated voltage, $U_0/U$ ( $U_m$ )	6,35/11 (12) kV
Rated maximum conductor temperature in normal operation	90 °C
Rated conductor cross-section	3x185 mm <sup>2</sup>
Thermal short-circuit current	22,5 kA

### 1.2 Characteristics of the outdoor termination for cables with extruded insulation

Manufacturer	Gala Shrink Fit, Mumbai, India
Type	heat-shrinkable outdoor termination
Type designation, reference number	GTM-OXAS-1233H6A ( GXO-13 )
Year of manufacture	2014
Rated voltage, $U_0/U$ ( $U_m$ )	6,35/11 (12) kV
No. of cores	3
Dynamic short-circuit current	not applicable
Creepage distance (minimum)	750 mm, including sheds
Flashover distance (minimum)	20 mm
Number of sheds	2
Material of insulating body	heat-shrinkable cross linked polyolefin anti-tracking material
Type of stress control	stress control mastic

### 1.3 Characteristics of the test cable

Note: the cable is not part of the type test.

Manufacturer (as stated by the client)	Apar Industries Limited, India
Type	$U_0 = 6$ kV 3x185 mm <sup>2</sup> Al/XLPE/CTS/PVC/SWA/PVC (A2XCEWY) CABLE
Manufacturing year	2014
Rated voltage, $U_0/U$ ( $U_m$ )	6/10 (12) kV
No. of cores	3
Core identification	core 1 = red core 2 = yellow core 3 = blue
Marking on the oversheath	AIL/UNIT: UNIFLEX CABLES- INDIA 'UNICAB' 6/10 (12) KV XLPE CABLE '3X185 Sq.mm 2014
Construction	see List of drawings

**Conductor**

- material aluminium
- cross-section 185 mm<sup>2</sup>
- nominal diameter 16,2 mm
- type stranded circular compacted
- maximum conductor temperature in normal operation 90 °C
- presence and nature of measures to achieve longitudinal watertightness no

**Conductor screen**

- material extruded semi-conducting compound
- nominal thickness 0,6 mm
- material designation extruded semi-conducting compound
- manufacturer of the material Hanwha and Sakun Polymer

**Insulation**

- material XLPE
- nominal thickness 3,4 mm

**Insulation (core) screen**

- material extruded semi-conducting compound
- strippable yes
- nominal thickness 0,5 mm

**Metal screen**

- material two annealed plain copper tape
- type helical
- nominal thickness and width of tape 0,03 x 40 mm (overlap 10%)
- nominal thickness and width of tape 2 x 40 mm (overlap 10%)
- cross-sectional area 27,6 mm<sup>2</sup> three cores together

**Inner coverings and fillers**

- material yes

**Separation sheath**

- material PVC, type ST<sub>2</sub>
- nominal thickness 1,6 mm
- manufacturer of the material Gala Shrink Fit, Mumbai, India

**Metal armour**

- material galvanised steel round wires
- number of wires 68
- nominal diameter of wires 2,5 mm
- cross-sectional area 333,8 mm<sup>2</sup>

**Metal foil or tape, longitudinally applied, no bonded to the oversheath**

**.Oversheath**

- material PVC, type ST<sub>2</sub>
- nominal thickness 3,3 mm
- nominal overall diameter of the cable (D) 72,0 mm
- material designation PVC, type ST2
- manufacturer of the material Gala Shrink Fit, Mumbai, India
- colour black

**.Manufacturing details insulation system**

- location of manufacturing Umbergaon, India
- type of extrusion line CCV
- type of extrusion triple common extrusion
- curing means dry
- cooling means dry
- manufacturing length (where cable sample for testing has been taken from) 100 m

#### 1.4 List of drawings

The manufacturer has guaranteed that the object submitted for tests has been manufactured in accordance with the following drawing and documents. KEMA has verified that these drawing and documents adequately represent the object tested. The manufacturer is responsible for the correctness of these drawing and documents and the technical data presented.

The following drawing and documents have been included in this Report:

Drawing No./document No.	Revision
GTSP/LK01/06/14	00

The following document is only listed for reference and is kept in KEMA's files:

Document no.	Revision/date
Components list GTM/OXAS/1233A	-
Jointing instruction GTM/XAS/31115	-

## 2 GENERAL INFORMATION

### 2.1 The tests were witnessed by

Name	Company
Mr Gurubax Singh 12 to 15 August 2014	Gala Shrink Fit, Mumbai, India

### 2.2 The tests were carried out by

Name	Company
Ms H. He	KEMA Nederland B.V., Arnhem, The Netherlands
Mr A. Sengers	
Mr T. Ariaans	
Mr E. Pultrum	
Mr D. Bouchier	
Mr N. Dobbe	
Mr K. Linden	

### 2.3 Measurement uncertainty

A table with measurement uncertainties is enclosed in this report. Unless otherwise stated, the measurement uncertainties of the results presented in this report are as indicated in that table.



### 3 TEST SEQUENCE 1.1 FOR OUTDOOR TERMINATION (TWO TERMINATIONS)

#### 3.1 Determination of the cable conductor temperature

##### 3.1.1 Determination of the cable conductor temperature


#### Standard

Standard IEC 60840, Annex A, Subclause A.3.1 was used as a guide

For the tests at elevated temperature, a reference loop for temperature control of the conductor was installed and conductor current was used for heating. The reference cable was cut from the total cable length intended for the type test. This reference loop was installed close to the main loop in order to create the same environmental conditions as for the test loop.

The heating currents in both the reference loop and the test loop were kept equal at all times, thus the conductor temperature of the reference loop is representative for the conductor temperature of the test loop. IEC 60840, Annex A was used as a guide and IEC 60840, Subclause A.3.1, method 1 was applied.

The tests at elevated temperature are carried out after the conductor temperature has been within the stated temperature limits for at least 2 hours. The test set-up was consisting of a joint as part of a cable system, also incorporating two outdoor terminations which are not part of the type test objects. The test set-up of two separate main test loops connected in series.



Sample 1 and 2 for test sequence 1.1

### 3.3 DC voltage dry

#### Standard and date

Standard IEC 60502-4, Table 5, test number 1  
Test date 12 August 2014

#### Environmental conditions

Ambient temperature 21 °C  
Temperature of test object 21 °C

Testing arrangement		Voltage applied, DC		Duration
Voltage applied to	Earth connected to	... x U <sub>0</sub>	(kV)	(min)
Conductor 1,2 and 3 of test loop 1	Metal screens	6	38	15
Conductor 1,2 and 3 of test loop 2	Metal screens	6	38	15

#### Note

On request of the client the test has been performed more severely at 6 x U<sub>0</sub> instead of 4 x U<sub>0</sub>.

#### Requirement

No breakdown or flashover shall occur.

#### Result

The object passed the test.

**3.4 AC voltage dry****Standard and date**

Standard IEC 60502-4, Table 5, test number 1

Test date 12 August 2014

**Environmental conditions**

Ambient temperature 21 °C

Temperature of test object 22 °C

Testing arrangement		Voltage applied, 50 Hz		Duration (min)
Voltage applied to	Earth connected to	... x U <sub>0</sub>	(kV)	
Conductor 1,2 and 3 of test loop 1	Metal screens	4,5	28,5	5
Conductor 1,2 and 3 of test loop 2	Metal screens	4,5	28,5	5

**Requirement**

No breakdown or flashover shall occur.

**Result**

The object passed the test.

### 3.5 AC voltage wet

#### Standard and date

Standard IEC 60502-4, Table 5, test number 1  
 Test date 13 August 2014

#### Environmental conditions

Ambient temperature 22 °C

#### Characteristic test data

Temperature of test object 22 °C  
 Temperature of water 22 °C  
 Vertical component 1,4 mm/min  
 Horizontal component 1,9 mm/min  
 Pre-wetting period > 15 min

Testing arrangement		Voltage applied, 50 Hz		Duration
Voltage applied to	Earth connected to	... x U <sub>0</sub>	(kV)	(min)
Conductor 1,2 and 3 of test loop 1	Metal screens	4	25,5	1
Conductor 1,2 and 3 of test loop 2	Metal screens	4	25,5	1

#### Requirement

No breakdown or flashover shall occur.

#### Result

The object passed the test.

### 3.6 Partial discharge at ambient temperature

#### Standard and date

Standard IEC 60502-4, Table 5, test number 2

Test date 13 August 2014

#### Environmental conditions

Ambient temperature 22 °C

#### Characteristic test data

Temperature of test object 22 °C  
 Circuit direct  
 Calibration 5 pC  
 Noise level at 1,73  $U_0$  2.5 pC  
 Declared sensitivity 5 pC  
 Required sensitivity  $\leq 5$  pC  
 Centre frequency 117,5 kHz  
 Bandwidth ( $\Delta f$ ) 100 kHz  
 Test frequency 50 Hz  
 Coupling capacitor 2600 pF

Core	Voltage applied, 50 Hz		Duration (s)	Partial discharge level (pC)
	... x $U_0$	(kV)		
1 of test loop 1	2	12,5	10	-
	1,73	11	-	Not detectable
2 of test loop 1	2	12,5	10	-
	1,73	11	-	Not detectable
3 of test loop 1	2	12,5	10	-
	1,73	11	-	Not detectable
1 of test loop 2	2	12,5	10	-
	1,73	11	-	Not detectable
2 of test loop 2	2	12,5	10	-
	1,73	11	-	Not detectable
3 of test loop 2	2	12,5	10	-
	1,73	11	-	Not detectable

#### Requirement

The maximum partial discharge level from the test object at 1,73  $U_0$  shall not exceed 10 pC.

#### Result

The object passed the test.

### 3.7 Impulse voltage at elevated temperature

#### Standard and date

Standard IEC 60502-4, Table 5, test number 3  
 Test date 26 August 2014

#### Environmental conditions

Ambient temperature 21 °C

#### Characteristic test data

Temperature of test object 97 °C  
 Specified test voltage 95 kV

Testing arrangement		Polarity	Voltage applied (% of test voltage)	No. of impulses	See figure on next pages
Voltage applied to	Earthed				
Conductor 1 test loop 1 and 2	Metal screens and conductor 2 and 3	Positive	50	1	1 (waveshape)
			65	1	2
			80	1	2
			100	10	3 and 4
Conductor 1 test loop 1 and 2	Metal screens and conductor 2 and 3	Negative	50	1	5 (waveshape)
			65	1	6
			80	1	6
			100	10	7 and 8
Conductor 2 test loop 1 and 2	Metal screens and conductor 1 and 3	Positive	50	1	9 (waveshape)
			65	1	10
			80	1	10
			100	10	11 and 12
Conductor 2 test loop 1 and 2	Metal screens and conductor 1 and 3	Negative	50	1	13(waveshape)
			65	1	14
			80	1	14
			100	10	15 and 16
Conductor 3 test loop 1 and 2	Metal screens and conductor 1 and 2	Positive	50	1	17 (waveshape)
			65	1	18
			80	1	18
			100	10	19 and 20
Conductor 3 test loop 1 and 2	Metal screens and conductor 1 and 2	Negative	50	1	21 (waveshape)
			65	1	22
			80	1	22
			100	10	23 and 24

#### Note

On request of the client the applied LI voltage was 95 kV instead of 75 kV.

**Requirement**

Each core of the cable and accessory shall withstand without failure 10 positive and 10 negative voltage impulses.

**Result**

The object passed the test.

### 3.8 Heating cycle voltage in air

#### Standard and date

Standard IEC 60502-4, Table 5, test number 4  
 Test dates 28 August to 9 October 2014

#### Environmental conditions

Ambient temperature 20-22 °C

#### Characteristic test data

Heating method conductor current  
 Stabilized temperature 97 °C

No. of heating cycles	Required steady conductor temperature (°C)	Heating current during steady condition (A)	Heating cycle			Voltage	
			Heating		Cooling	Total duration (h)	Voltage applied 2,5 U <sub>0</sub> (kV)
			Total duration (h)	Duration of conductor at steady temperature (h)	Total duration (h)		
126	95-100	approx. 409	5	2	4	9	16

#### Note

On request of the client the applied number of heating cycles was 126 instead of 60.

#### Requirement

No breakdown shall occur.

#### Result

The object passed the test.



### 3.9 Immersion

#### Standard and date

Standard IEC 60502-4, Table 5, test number 5  
 Test dates 4 to 8 November 2014

#### Environmental conditions

Ambient temperature 20-22 °C

#### Characteristic test data

Heating method conductor current  
 Stabilized temperature 97 °C  
 Height above every part of the termination 0,03-0,05 m

No. of heating cycles	Required steady conductor temperature (°C)	Heating current during steady condition (A)	Heating cycle		
			Heating		Cooling
			Total duration (h)	Duration of conductor at steady temperature (h)	Total duration (h)
10	95 - 100	approx. 413	5	2	4

#### Requirement

The test shall be carried out successfully.

#### Result

The object passed the test.

3.10 **Partial discharge at elevated and ambient temperature**

3.10.1 **Partial discharge at elevated temperature**

**Standard and date**

Standard IEC 60502-4, Table 5, test number 6  
 Test date 11 November 2014

**Environmental conditions**

Ambient temperature 20 °C

**Characteristic test data**

Temperature of test object 97 °C  
 Circuit direct  
 Calibration 5 pC  
 Noise level at 1,73 U<sub>0</sub> 2 pC  
 Declared sensitivity 4 pC  
 Required sensitivity ≤ 5 pC  
 Centre frequency 98 kHz  
 Bandwidth (Δf) 100 kHz  
 Test frequency 50 Hz  
 Coupling capacitor 2600 pF

Core	Voltage applied, 50 Hz		Duration (s)	Partial discharge level (pC)
	... x U <sub>0</sub>	(kV)		
1 of test loop 1 and 2	2	12,5	10	-
	1,73	11	-	Not detectable
2 of test loop 1 and 2	2	12,5	10	-
	1,73	11	-	Not detectable
3 of test loop 1 and 2	2	12,5	10	-
	1,73	11	-	Not detectable

**Requirement**

The maximum partial discharge level from the test object at 1,73 U<sub>0</sub> shall not exceed 10 pC.

**Result**

The object passed the test.

### 3.10.2 Partial discharge at ambient temperature

#### Standard and date

Standard IEC 60502-4, Table 5, test number 6  
 Test date 13 November 2014

#### Environmental conditions

Ambient temperature 20 °C

#### Characteristic test data

Temperature of test object 20 °C  
 Circuit direct  
 Calibration 5 pC  
 Noise level at 1,73 U<sub>0</sub> 2,5 pC  
 Declared sensitivity 5 pC  
 Required sensitivity ≤ 5 pC  
 Centre frequency 124,5 kHz  
 Bandwidth (Δf) 100 kHz  
 Test frequency 50 Hz  
 Coupling capacitor 2600 pF

Core	Voltage applied, 50 Hz		Duration (s)	Partial discharge level (pC)
	... x U <sub>0</sub>	(kV)		
1 of test loop 1 and 2	2	12,5	10	-
	1,73	11	-	Not detectable
2 of test loop 1 and 2	2	12,5	10	-
	1,73	11	-	Not detectable
3 of test loop 1 and 2	2	12,5	10	-
	1,73	11	-	Not detectable

#### Requirement

The maximum partial discharge level from the test object at 1,73 U<sub>0</sub> shall not exceed 10 pC.

#### Result

The object passed the test.

### 3.11 Impulse voltage at ambient temperature

#### Standard and date

Standard IEC 60502-4, Table 5, test number 10

Test date 14 November 2014

#### Environmental conditions

Ambient temperature 20 °C

#### Characteristic test data

Temperature of test object 20 °C

Specified test voltage 95 kV

Testing arrangement		Polarity	Voltage applied (% of test voltage)	No. of impulses	See figure on next pages
Voltage applied to	Earthed				
Conductor 1 of test loop 1 and 2	Metal screens and conductor 2 and 3	Positive	50	1	1 (waveshape)
			65	1	2
			80	1	2
			100	10	3 and 4
Conductor 1 of test loop 1 and 2	Metal screens and conductor 2 and 3	Negative	50	1	5 (waveshape)
			65	1	6
			80	1	6
			100	10	7 and 8
Conductor 2 of test loop 1 and 2	Metal screens and conductor 1 and 3	Positive	50	1	9 (waveshape)
			65	1	10
			80	1	10
			100	10	11 and 12
Conductor 2 of test loop 1 and 2	Metal screens and conductor 1 and 3	Negative	50	1	13 (waveshape)
			65	1	14
			80	1	14
			100	10	15 and 16
Conductor 3 of test loop 1 and 2	Metal screens and conductor 1 and 2	Positive	50	1	17(waveshape)
			65	1	18
			80	1	18
			100	10	19 and 20
Conductor 3 of test loop 1 and 2	Metal screens and conductor 1 and 2	Negative	50	1	21 (waveshape)
			65	1	22
			80	1	22
			100	10	23 and 24

#### Note

On request of the client the applied LI voltage was 95 kV instead of 75 kV.

**Requirement**

Each core of the cable and accessory shall withstand without failure 10 positive and 10 negative voltage impulses.

**Result**

The object passed the test.

3.12 AC voltage dry

**Standard and date**

Standard IEC 60502-4, Table 5, test number 11  
Test date 17 November 2014

**Environmental conditions**

Ambient temperature 20 °C  
Temperature of test object 20 °C

Testing arrangement		Voltage applied, 50 Hz		Duration (min)
Voltage applied to	Earth connected to	... x U <sub>0</sub>	(kV)	
Conductor 1,2 and 3 of test loop 1 and 2	Metal screens	2,5	16	15

**Requirement**

No breakdown or flashover shall occur.

**Result**

The object passed the test.

### 3.13 Examination

#### Standard and date

Standard IS 13573 (part 2), table 2, test xiv)  
Test date 1 December 2014

#### Environmental conditions

Ambient temperature 21 °C  
Temperature of test object 21 °C

Test loop	Observations <sup>1)</sup>
1 and 2	None of the following has been detected: <ul style="list-style-type: none"><li>- cracking in the filling material and/or tape or tubing components</li><li>- a moisture path bridging a primary seal</li><li>- corrosion and/or tracking and/or erosion</li><li>- leakage of any insulating material</li></ul>

1) Photographs of the examination are presented on the next page

#### Result

The results are for information only.

#### 4 TEST SEQUENCE 1.2 FOR OUTDOOR TERMINATION (ONE TERMINATION)

##### 4.1 Test arrangement

##### 4.1.1 Determination of the cable conductor temperature

**Standard**


Standard

IEC 60840, Annex A, Subclause A.3.1 was used as a guide

For the tests at elevated temperature, a reference loop for temperature control of the conductor was installed and conductor current was used for heating. The reference cable was cut from the total cable length intended for the type test. This reference loop was installed close to the main loop in order to create the same environmental conditions as for the test loop.

The heating currents in both the reference loop and the test loop were kept equal at all times, thus the conductor temperature of the reference loop is representative for the conductor temperature of the test loop. IEC 60840, Annex A was used as a guide and IEC 60840, Subclause A.3.1, method 1 was applied.

The tests at elevated temperature are carried out after the conductor temperature has been within the stated temperature limits for at least 2 hours. The test set-up was consisting of a joint as part of a cable system, also incorporating a heat-shrinkable outdoor termination and a heat-shrinkable indoor termination.



Sample 3 for test sequence 1.2



## 4.2 DC voltage dry

### Standard and date

Standard IEC 60502-4, Table 5, test number 1  
Test date 12 August 2014

### Environmental conditions

Ambient temperature 21 °C  
Temperature of test object 22 °C

Testing arrangement		Voltage applied, DC		Duration (min)
Voltage applied to	Earth connected to	... x U <sub>0</sub>	(kV)	
Conductor 1,2 and 3 of test loop 3	Metal screens	6	38	15

### Note

On request of the client the test has been performed more severely at 6 x U<sub>0</sub> instead of 4 x U<sub>0</sub>.

### Requirement

No breakdown or flashover shall occur.

### Result

The object passed the test.

### 4.3 AC voltage dry

#### Standard and date

Standard IEC 60502-4, Table 5, test number 1  
Test date 12 August 2014

#### Environmental conditions

Ambient temperature 21 °C  
Temperature of test object 22 °C

Testing arrangement		Voltage applied, 50 Hz		Duration (min)
Voltage applied to	Earth connected to	... x U <sub>0</sub>	(kV)	
Conductor 1,2 and 3 of test loop 3	Metal screens and conductor 2 and 3	4,5	28,5	5

#### Note

The test was more severe than the requirement; both the DC voltage test and the AC voltage test is conducted.

#### Requirement

No breakdown or flashover shall occur.

#### Result

The object passed the test.

#### 4.4 Thermal short circuit test (screen)

##### Standard and date

Standard IEC 60502-4, Table 5, test number 7  
 Test date 9 January 2015

##### Environmental conditions

Ambient temperature 22 °C

##### Characteristic test data

Stabilized conductor temperature 97 °C

Conductor heating		
Required conductor temperature $\theta$ (°C)	Applied 3-phase heating current (A)	Conductor stable at 97 °C before short-circuit application (h)
$95 \leq \theta \leq 100$	530	2

Short-circuit application on screen (see figures on the next pages)			
Specified short-circuit current (kA)	Frequency (Hz)	Duration (s)	Number of short-circuit applications
2,5	50	1	2

##### Procedure

The conductor temperature shall be maintained within the stated temperature limits for at least 2 h before carrying out the short-circuit test. Between the two short-circuit applications, the cable screen shall be allowed to cool down to a temperature less than 10 K above its temperature prior to the first short-circuit application.

##### Requirement

No visible deterioration may occur.

##### Result

The object passed the test.

#### 4.5 Thermal short circuit test (conductor)

##### Standard and date

Standard IEC 60502-4, Table 5, test number 8  
 Test date 28 January 2015

##### Environmental conditions

Ambient temperature 11 °C

##### Characteristic test data

Conductor material Aluminum  
 Cross section conductor 185 mm<sup>2</sup>  
 Maximum short circuit conductor temperature 250 °C

##### First short circuit application

Start temperature of test object (measured value) 13,5 °C  
 Selected duration of short circuit current 1 s  
 Calculated short circuit current 22,5 kA  
 Thermal current, three phase 22,7 kA  
 Duration 1,06 s


##### Second short circuit application

Start temperature of test object (measured value) 13,5 °C  
 Selected duration of short circuit current 1 s  
 Calculated short circuit current 22,5 kA  
 Thermal current, three phase 22,7 kA  
 Duration 1,05 s

##### Procedure

Two short-circuits shall be applied to raise the conductor temperature to the maximum permissible short-circuit temperature of the cable within 5 s. Between the two short-circuits, the test loop shall be allowed to cool to a temperature less than 10 K above its temperature prior to the first short-circuit.

4.6 Test circuit S01




G = Generator      TO = Test Object      U = Voltage Measurement to earth  
 MB = Master Breaker      L = Reactor      I = Current Measurement  
 MS = Make Switch  
 PT = Power Transformer

Supply		
Power	MVA	47,2
Frequency	Hz	50
Phase(s)		3
Voltage	kV	2,2
Current	kA	22
Impedance	$\Omega$	0,033
Power factor		< 0,1
Neutral		Not earthed

Load	
Short-circuit point	earthed


### 4.7 Test results and oscillograms

Thermal short-circuit test



Test number: 150128-6005



Phase		-	-	-
Peak value of current	kA	-42,6	38,7	38,1
Symmetrical current, beginning	kA	23,0	23,5	23,3
Symmetrical current, middle	kA	22,7	23,1	22,8
Symmetrical current, end	kA	22,5	22,9	22,7
Symmetrical current, average	kA	22,8	23,3	22,1
Average current, three phase	kA	22,7		
Current duration	s	1,05	1,05	1,05
Thermal equivalent		22,5 kA during 1,06 s		



Ambient temperature 13,5 °C

Remarks:

Thermal short-circuit test



Test number: 150128-6006

Phase		-	-	-
Peak value of current	kA	-42,3	38,6	37,9
Symmetrical current, beginning	kA	23,0	23,4	23,2
Symmetrical current, middle	kA	22,6	23,0	22,7
Symmetrical current, end	kA	22,5	22,9	22,6
Symmetrical current, average	kA	22,8	23,2	22,0
Average current, three phase	kA	22,7		
Current duration	s	1,05	1,05	1,05
Thermal equivalent		22,5 kA during 1,10 s		

Ambient temperature 13,5 °C

Remarks:

4.8 **Condition / inspection after test**

**Requirement**

No visible deterioration may occur.

**Result**

No visible change. No visible damage.  
The object passed the test.



4.9 Impulse voltage at ambient temperature

**Standard and date**

Standard IEC 60502-4, Table 5, test number 10  
 Test date 29 January 2015

**Environmental conditions**

Ambient temperature 20 °C

**Characteristic test data**

Temperature of test object 20 °C  
 Specified test voltage 95 kV

Testing arrangement		Polarity	Voltage applied (% of test voltage)	No. of impulses	See figure on next pages
Voltage applied to	Earthed				
Conductor 1 test loop 3	Metal screens and conductor 2 and 3	Positive	50	1	1 (waveshape)
			65	1	2
			80	1	2
			100	10	3 and 4
Conductor 1 test loop 3	Metal screens and conductor 2 and 3	Negative	50	1	5 (waveshape)
			65	1	6
			80	1	6
			100	10	7 and 8
Conductor 2 test loop 3	Metal screens and conductor 1 and 3	Positive	50	1	9 (waveshape)
			65	1	10
			80	1	10
			100	10	11 and 12
Conductor 2 test loop 3	Metal screens and conductor 1 and 3	Negative	50	1	13 (waveshape)
			65	1	14
			80	1	14
			100	10	15 and 16
Conductor 3 test loop 3	Metal screens and conductor 1 and 2	Positive	50	1	17(waveshape)
			65	1	18
			80	1	18
			100	10	19 and 20
Conductor 3 test loop 3	Metal screens and conductor 1 and 2	Negative	50	1	21 (waveshape)
			65	1	22
			80	1	22
			100	10	23 and 24

**Note**

On request of the client the applied LI voltage was 95 kV instead of 75 kV.

**Requirement**

Each core of the cable and accessory shall withstand without failure 10 positive and 10 negative voltage impulses.

**Result**

The object passed the test.

4.10 AC voltage dry

**Standard and date**

Standard IEC 60502-4, Table 5, test number 11  
Test date 29 January 2015

**Environmental conditions**

Ambient temperature 20 °C  
Temperature of test object 20 °C

Testing arrangement		Voltage applied, 50 Hz		Duration (min)
Voltage applied to	Earth connected to	... x U <sub>0</sub>	(kV)	
Conductor 1,2 and 3 of test loop 3	Metal screens	2,5	16	15

**Requirement**

No breakdown or flashover shall occur.

**Result**

The object passed the test.

### 4.11 Examination

#### Standard and date

Standard IS 13573 (part 2), table 2, test xiv)  
Test date 5 February 2015

#### Environmental conditions

Ambient temperature 20 °C  
Temperature of test object 20 °C

Test loop	Observations <sup>1)</sup>
3	None of the following has been detected: <ul style="list-style-type: none"><li>- cracking in the filling media and/or tape or tube components</li><li>- a moisture path across a primary seal</li><li>- corrosion and/or tracking and/or erosion</li><li>- leakage of any insulating material</li></ul>

1) Photographs of the examination are presented on the next page

#### Result

The results are for information only.

## 5 TEST SEQUENCE 1.5 (ONE OUTDOOR TERMINATION)

### 5.1 Salt fog

#### Standard and date

Standard IEC 60502-4, Table 5, test number 13

Test dates 11 February to 23 March 2015

#### Environmental conditions

Ambient temperature 20-22 °C

Temperature of test object 20-22 °C

#### Characteristic test data

Leakage current protection  $1 \pm 0,1$  A

( $I_{max}$ )

Conductivity  $1600 \pm 200$  mS/m

Rate of flow  $0,4 \pm 1$  l/h/m<sup>3</sup>

Testing arrangement		Applied Voltage, 50 Hz		Duration (h)
Voltage applied to conductor	Earth connected to	... x U <sub>0</sub>	(kV)	
1, 2 and 3	Metallic screen	1,25	8	1000

#### Requirement

No breakdown or flashover, no more than 3 trips, no substantial damage of the insulation shall occur.

#### Result

There was no breakdown or flashover, no trips.

After the salt fog test, loss of dielectric quality due to tracking and/or erosion was found on one of the three phases.

## 5.2 Examination

### Standard and date

Standard IS 13573 (part 2), table 2, test xiv)

Test date 23 March 2015

### Environmental conditions

Ambient temperature 20 °C

### Characteristic test data

Temperature of test object 20 °C

Object	Observations
Test loop 4	None of the following has been detected: <ul style="list-style-type: none"><li>- cracking in the filling media and/or tape or tube components</li><li>- a moisture path across a primary seal</li><li>- corrosion and/or tracking and/or erosion</li><li>- leakage of any insulating material</li></ul>

### Result

For information only.

6

DRAWING

3 Core XLPE Cable

S.No	DESCRIPTION
1	CONDUCTOR
2	INSULATION
3	SEMI CONDUCTIN SCREEN
4	METAL SHIELD
5	OUTER SHEATH
6	TERMINAL SLEEVE
7	ANTI TRACKING WEATHER RESISTANT TUBING
8	STRESS CONTRL TUBING
9	RAIN SHED
10	ANTI TRACKING CABLE BREAK OUT
11	TINNED COPPER EARTH BRAID (MAIN EARTH)
12	ARMOUR
13	INNER SHEATH
14	JUBILEE CLAMPS
15	MASTIC SEALING TAPE
16	TERMINAL LUG
17	LUG SEALING MASTIC RED
18	ROLL SPRING
19	SEMI CONDUCTIVE PAINT +STRESS CONTROL MASTIC
20	SILICON GREASE
21	ALOXITE EMERY TAPE
22	MOPPING CLOTH

**CABLE COMPONENTS (MAJOR PARTS)**

**LEGENDS**

○ KIT CONTENTS (INSTALLATION AIDS)

△ LENGTH OF SEMI CONDUCTING SCREEN OF CORE

□ LENGTH OF METALLIC SHIELDING OF CORE

◇ LENGTH OF INNER SHEATH

◇◇ LENGTH OF ARMOUR

**LEGENDS**

△ MOPPING CLOTH

△ ALOXITE EMERY TAPE

△ SILICON GREASE

□ ROLL SPRING

◇ SEMI CONDUCTIVE PAINT +STRESS CONTROL MASTIC

◇◇ LUG SEALING MASTIC RED

◇◇ TERMINAL LUG

◇◇ MASTIC SEALING TAPE

◇◇ JUBILEE CLAMPS

◇◇ INNER SHEATH

◇◇ ARMOUR

◇◇ TINNED COPPER EARTH BRAID (MAIN EARTH)

◇◇ ANTI TRACKING CABLE BREAK OUT

◇◇ RAIN SHED

◇◇ STRESS CONTRL TUBING

◇◇ ANTI TRACKING WEATHER RESISTANT TUBING

◇◇ TERMINAL SLEEVE

◇◇ OUTER SHEATH

◇◇ METAL SHIELD

◇◇ SEMI CONDUCTIN SCREEN

◇◇ INSULATION

◇◇ CONDUCTOR

**GA** GALA Shrink Fit  
MUMBAI - 401 105 (INDIA)

**CABLINK**

Title :- HEAT SHRINKABLE OUTDOOR TERMINATION SUITABLE FOR 6.35/12KV (U max: 12KV) 3 CORE XLPE ARMORED CABLES

Scale : MIS

REV. No. 00

Drawn By : S. Kumar

Appd. By : A.K.Shaw

DATE : 10/06/14

240-400	80	20	100	50
150-185	80	20	100	50
70-120	60	20	100	50
16-50	50	20	100	50
CABLE SIZE (Sq.mm)	L1	L2	L3	L4

CABLE CUTTING DIMENSIONS FOR 3 CORE CABLES

## 7 MEASUREMENT UNCERTAINTY

The measurement uncertainties in the results presented are as specified below unless otherwise indicated.

Measurement	Measurement uncertainty
Dielectric tests and impulse current tests:	
- peak value	≤ 3%
- time parameters	≤ 10%
Capacitance measurement	0,3%
Tan δ measurement	± 0,5% ± 5 × 10 <sup>-5</sup>
Partial discharge measurement:	
- < 10 pC	2 pC
- 10 to 100 pC	5 pC
- > 100 pC	20%
Measurement of impedance AC-resistance measurement	≤ 1%
Measurement of losses	≤ 1%
Measurement of insulation resistance	≤ 10%
Measurement of DC resistance:	
- 1 to 5 μΩ	1%
- 5 to 10 μΩ	0,5%
- 10 to 200 μΩ	0,2%
Radio interference test	2 dB
Calibration of current transformers	2,2 × 10 <sup>-4</sup> I <sub>p</sub> /I <sub>u</sub> and 290 μrad
Calibration of voltage transformers	1,6 × 10 <sup>-4</sup> U <sub>p</sub> /U <sub>u</sub> and 510 μrad
Measurement of conductivity	5%
Measurement of temperature:	
- -50 to -40 °C	3 K
- -40 to 125 °C	2 K
- 125 to 150 °C	3 K
Tensile test	1%
Sound level measurement	type 1 meter as per IEC 60651 and ANSI S1,4,1971
Measurement of voltage ratio	0,1%